

The Foundation Layer

## Series 70 ePODs: Type-maX

Industrial Load Center



# The LayerZero ePODs: Type-maX PDU Maximizes Operator Safety

#### ePODs Type-maX Is Inspired by NFPA-70E

The Series 70 ePODs: Type-maX is a Power Distribution Unit for industrial applications with high reliability requirements. It features an NFPA 70E friendly design, sectionalized layout, and the IP-20 rated Finger-Safe SafePanel, to help protect operators and ensure safe operation. With an emphasis on reliability, safety, power quality monitoring, and connectivity, the Series 70 ePODs: Type-maX provides high-reliability power distribution. The Series 70 ePODs: Type-maX is designed to be easy to work with, to minimize risk during installation, ideal for growing or constantly changing environments.







#### LayerZero's ePODs: Type-maX Product Features

#### Reliability

- Silver Plated Input Terminals: Silver Has Excellent Conductivity To Provide Superior Electrical Performance and Reliability
- Machined Hardware: Machined Cap Screws and Engineered Disc Springs Maintain Constant Torque Throughout Product Life
- Screw Thread Inserts: Prevents Screws From Loosening Under Vibration For Long-Term Reliability
- Serialized Critical Board Tracking: Critical Boards Are Serialized And Cataloged in an Active Database For Traceability
- ☑ Transformer Vibration Isolation: Vibro-Elastic Pads to Absorb Vibrations from the Transformer

#### Safety

- ☑ InSight<sup>™</sup> IR Portholes: Bolted Connections Can Be IR Scanned With the Dead-Front Doors Closed
- Sectionalized Components: Separations Between Each Section To Maintain Maximum Operator Safety
- Polycarbonate Windows: Allows Circuit Breaker Positions To Be Viewed With The Dead-Front Door Closed
- Dead Front Hinged Doors: Barrier To Provide A Safe Working Area With No Exposed Live Parts
- ☑ **Guided Wireways:** Helps Keep Wires Organized

#### Connectivity

- **Ethernet Connectivity:** Secure VPN Router Connects To Network For Advanced Remote Monitoring Capabilities
- Modbus/TCP: Open Connectivity to Existing Monitoring Systems Without Proprietary Limitations
- ☑ NTP Time Clock Synchronization: Facilitates Timeline-Based Logging For Post-Event Reconstruction
- SNMP Connectivity: Permits Remote Management Via Simple Network Management Protocol
- Discrete Set Up Panels At The Point-Of-Impact

#### **⊙ZEN** DPQM

- **Real-Time Waveform Capture:** Automatically Captures A Picture Of The Power Six-Cycles Before and After Every Event
- **Optional Local Touch-Screen Interface:** Password-Protected Color Touch-Screen GUI For Local ePODs Setup/Operation
- **Black-Box Forensics:** ePODs Captures and Records Events To Provide Vital Information In Root-Cause Analysis

All LayerZero products break down power sources into samples for power quality analysis. This data is remotely accessible by connecting to the units via web browser.

The following "voltage sag" factory test was performed on a LayerZero Series 70 ePODs: Type-X PDU. Each phase is represented by a colored line, plotting the voltage over a period of time.

In the example below, the voltage of all three phases dropped below the user-defined setpoint, which triggered an undervoltage event, an automatic waveform capture, and an ITIC plot of the event.

On LayerZero PDUs and RPPs, waveforms and ITIC plots are generated for every phase, on every circuit, for every event.





#### **Equipment Layout**

Main Circuit Breaker Section: -Auxiliary MCB optional Mounting: Fixed, Plug-In Type: Molded Case Switch 65kA, 100kA Electronic Trip 65kAIC, 100kAIC Accessories: CB Shunt-trip 120VAC, 24VDC CB Position Indication: Open, Tripped, Closed

Monitoring Section: \_\_\_\_\_ Color-Touch Screen Interface Option Local/Remote EPO Option



ePODs: Type-maX Feeds from STS Output



### **Reliability Features**

#### **Silver Plated Terminals**

LayerZero utilizes silver plating on all input terminals to be able to provide the highest performance. Silver has high conductivity and low resistance - which makes for a great contact.

#### **Machined Hardware**

Our bolted connections utilize machined cap screws and engineered disc springs. The result is a flat pressure vs deflection profile to ensure that all bolted connections maintain constant torque through the life of the product.

These technologies have been well tested in disparate environments of wide temperature ranges to help ensure that, once connections have been tightened, they stay that way.

#### **Serialized Circuit Boards**

We serialize and track all critical circuit boards and memory cards through our eBOSS portal, which allows customers to reference which components their machines are made from, who tested the components, as well as the ability to view notes generated from testing.

Serialized components offer the ability to drill-down on prospective component failure utilizing predictive modeling techniques, so if part fails, the instance can be cross-referenced with similar parts. This preventative maintenance helps ensure maximum uptime.

#### **Vibration Isolation Damper Mounts**

Transformers in the Series 70: ePODs Type-maX Power Distribution Unit are equipped with vibration isolation damper mounts, helping to reduce the amount of vibration and noise that originates from transformers, ultimately leading to a higher reliability of electrical and mechanical connections over the life of the product.









#### Safety

#### View Status LEDs and Distribution CB Positions With Dead-Front Doors Closed

Our Series 70 product line was inspired by NFPA-70E, to help data centers drastically reduce the risks of their energy distribution systems.

Operators can view the status of diagnostic LEDs without exposure to the energized power electronics section. In addition, SafePanel circuit breaker positions can be viewed with the dead-front door closed.



#### **De-Energizable Monitoring Section**

To help make maintenance easier and safer, the ePODs: TypemaX is equipped with fuses. The fuses allow the Zen DPQM Panel Board Monitor to be safely replaced or upgraded.





#### **Safety Features**

#### The LayerZero 1200 A Finger-Safe SafePanel™

The LayerZero 1200 A SafePanel<sup>™</sup> Panel Board is a finger safe panel board with no exposed live parts.

The 1200 A SafePanel<sup>™</sup> optionally includes shrouds, covering unused spaces, maximizing operator safety.





The Breaker Is Inserted Into The SafePanel



Screws Help Secure The Breaker



The Handle Is Unlocked



For Maximum Safety, The SafePanel Has Recessed Bus Work And IP-20 Finger Safe Lattice.



#### **Connectivity Options**

#### Bluetooth Keeps Circuit Level Information Up-To-Date

Coordinate efforts to keep panel board naming conventions accurate and up-to-date with Bluetooth connectivity. In critical facilities, Facilities typically install the physical circuit breakers, while IT workers manage naming of panel designations.

With Bluetooth connectivity, the naming, size, and assignment of circuit breakers can be taken care of at the point-of-impact, bringing together the efforts of facilities and IT for more accurate deployment.









#### **Power Quality Monitoring**

# • Zen DPQM

The Series 70 ePODs: Type-maX is equipped with Zen DPQM (Distribution Power Quality Monitoring), an all encompassing monitoring system with local and remote communications options.

From basic monitoring & alarm reporting, to advanced power quality monitoring functionality, Zen DPQM provides a wide-range of options to help you be aware, be vigilant, be proactive in your quest to create a safe, stable and reliable operation.

Image: Angle of the second s	Ins Voltage Panel 2 web/in 19/17/2015 also an web/in 19/17/2015 also and 19/17/2015 also also and 19/17/2015 also also also also 19/17/2015 also also also 19/17/2015 also also also 19/17/2015 also also also 19/17/2015	A Backs A B	11 12 14 15 15 15 15 15 15 15 15 15 15	
Note     Note     Note     Note       Note     Section     Section     Section       Note     Section     Section     Section       Note     Section     Section     Section       Note     Section     Section     Section       Note     Section     Section     Section     Section       Note     Section <t< th=""><th>Ins Voltage Panel 2 web/in 19/17/2015 also an web/in 19/17/2015 also and 19/17/2015 also also and 19/17/2015 also also also also 19/17/2015 also also also 19/17/2015 also also also 19/17/2015 also also also 19/17/2015 also 19/17/2015</th><th>A Backs A B</th><th>11 12 14 15 15 15 15 15 15 15 15 15 15</th><th></th></t<>	Ins Voltage Panel 2 web/in 19/17/2015 also an web/in 19/17/2015 also and 19/17/2015 also also and 19/17/2015 also also also also 19/17/2015 also also also 19/17/2015 also also also 19/17/2015 also also also 19/17/2015	A Backs A B	11 12 14 15 15 15 15 15 15 15 15 15 15	
Name         Name <th< th=""><th>whether (14/2/14/23 state) and and an advectory of the sectory of the sector</th><th>A Backs A B</th><th>11 12 14 15 15 15 15 15 15 15 15 15 15</th><th></th></th<>	whether (14/2/14/23 state) and and an advectory of the sectory of the sector	A Backs A B	11 12 14 15 15 15 15 15 15 15 15 15 15	
Market         Market         Market         Market           Notation         Notation         Notation         Notation           Notatioon         Notatioon         Notatioon	whether (14/2/14/23 state) and and an advectory of the sectory of the sector	n Inde official offic	11 12 14 15 15 15 15 15 15 15 15 15 15	
No. 0     Mon. 0       Manual Markadow     Antione       Markadow     Anti	A - Contract - Co	Parks with time with time with time with time with time with time with time with time proved	11 12 14 15 15 15 15 15 15 15 15 15 15	
Part     Main C     Main C     Addition       Marcia     Main C     Main C     Main C       Main C     Main C	Size (J) Reave (S)           Size (R) Reave (S)	unde tens ande tens ande tens ande tens ande tens ande tens ander	11 12 14 15 15 15 15 15 15 15 15 15 15	
None (Limon)         None (Limon)         None (Limon)         None (Limon)           None (Limon)         None (Limon)         None (Limon)	S (<) Minut C     S (<) M	or the land or the land or the land or the land for the land dataset dataset dataset dataset dataset dataset dataset dataset dataset dataset dataset	64 100.4 100.4 100.4 100.4 1 1 40.4 10 10 10 10 10	
Non-Sec         Non-Sec <t< td=""><td></td><td>shines shines shines here pend pend pend pend pend pend pend pen</td><td>1014 1014 1014 101 1 1445 10 10 10</td><td></td></t<>		shines shines shines here pend pend pend pend pend pend pend pen	1014 1014 1014 101 1 1445 10 10 10	
Wate of Basic         Market         Autom           Wate of Basic         Nation         Nation         Nation           Service         Nation         Nation         Nation         Nation           Nation         Nation         Nation         Nation         Nation           Nation         Nation	10 - 60 Provide energy energy YMSC     44 Actually     44 YMSC     44 Actually     44 YMSC     44 Actually     44 YMSC     44 Actually     44 YMSC     44 YM	adi Mi Ng Ng Anat Anat Anat Anat Anat Anat Anat Anat	863 813 846 8 8 8 8 8 8 8 8 8 8 8 8 8 8 8 8 8 8	
National     Page 10     0.4     0.2       Balan     Page 10     Page 10     Page 10       <	when we frysteller strengt of an forsteller we forsteller strengt of website forstell website forstell website forstell website forsteller densite forsteller d	ing anat Anat Anat Anat Anat Anat Anat	8.1 1 44C 10 10	
Num S     Alles Malain     - 4-5       Sym     Damin Sharing     Partier     0       Sym Sharing     Partier     0     0       Sym Sharing     Partier     Partier     0     0       Sym Sharing     Sym Sharing     Partier     0     0       Sym Sharing     Partier     Partier     0     0       Sym Sharing     Partier     Partier     0     0       Sym Sharing     Partier     Partier     0     0	A factor Indep Engent Verlage Sequent Verlage Sequent Verlage Sequent A request Sequent Sequent Sequent Sequent Sequent A factor Sequent Sequent A factor Sequent Sequent A factor Sequent Sequent A factor Sequent Sequent Sequent Sequent Sequent Sequent Sequent Sequent Sequent Sequent Sequent Sequent Sequent Se	anad pros anad pros pros pros pros pros pros	+44C 10 10	
Sector     Sector     Sector       Sect	er Volkge Segue Volkge Segue Volkge Segue Volkge Segue Volkge Segue Volkge Segue Volkge Segue Volkge Segue S	aran Aran Aran Aran Aran Aran Aran		
Les Marting Statest         and         a           Les Marting Statest         and         a           Daile Statest Statest         and         a         a           Daile Statest         and statest         a	Induce Ensured Volues Ensured Volues Ensured Projectors Ensured Projectors Ensured Database Ensured Excelose A Labor A	aran Aran Aran Aran Aran Aran Aran	129	
Sin Status         Sin         Dis           Die Status         Person         Die           Die Status         Person         Die         Die	Votage Stephent Ar Frequence Stephent Providente Stephent Database Stephent a 4 - Unit Votage 8 - Unit Votage 4 - Unit Votage 4 - Unit Votage	1111	129	
Disk Prison         Part         B           Disk PristPristPrison         Part         B <td>Insparso Second Insparso Second Decision Second Decision Second d - Scher Windpe d - Scher Windpe</td> <td>print print acost print</td> <td></td> <td></td>	Insparso Second Insparso Second Decision Second Decision Second d - Scher Windpe d - Scher Windpe	print print acost print		
Sub Region Marcin     Jack     Jack       Sub Region Marcin     Participa     Jack       Res & Sub Printing     Participa     Control       Res & Participa     Participa     Participa       Res & Participa     Parting	Pressent Setand Desinitian Setand Desinitian Setand a Autorium a A - Londre Hullage a C - Delare Hullage a C - Delare Hullage a X - Long Withole	perset. perset	*	
Big Solution Solution     event     p       High Solution Solution     event     event       High Solution     event       High Solution     event <td>: Dalontan Selpone a Kateron a K. Uniter Wallage a B. Joséer Wallage a K. Laker Wallage a K. Laker Wallage b J. Laker Wallage</td> <td>provi</td> <td></td> <td>/</td>	: Dalontan Selpone a Kateron a K. Uniter Wallage a B. Joséer Wallage a K. Laker Wallage a K. Laker Wallage b J. Laker Wallage	provi		/
Name     Sector     Sector       Name     Lobit Inform     Ann     Con       Name     Lobit Inform     Anno     Con	a katerier a 4 - Uniter Hollage a 8 - Davier Hollage a 6 - Davier Hollage a 4 - Lake Hollage a 4 - Lake Hollage		15	
Mark 4: Jaho Malan     Mark     California       Mark 6: Jaho Malan     Mark     California       Mark 7: Jaho Malan     Mark     California       Mark 7: Jaho Malan     Mark     California       Mark 8: Jaho Malan     Mark     California       Mark 9: Jaho Malan     Mark     California <td>e V - De Angele e V -</td> <td></td> <td>340</td> <td></td>	e V - De Angele e V -		340	
Partel     Solution     Solution       Markel     Loss Markel     Solution <td>er C - Deder Voltage ar A - Low Voltage ar B - Low Voltage</td> <td>441</td> <td>C.C.</td> <td></td>	er C - Deder Voltage ar A - Low Voltage ar B - Low Voltage	441	C.C.	
National Callo Martine Martine Callo Martine Martine Martine Callo Martine Martine Callo Martine Martine Call	e A - Low Vyllage	Alarta	2003	
Natel - Lan Houpe     Market     Common		Barby .	0000	
A fast i kalj kologi Marti i kaj kologi Marti i kologi		aares	CON.	
Basel 4. Solubility     Basel     Basel       Facel 4. Solubility     Basel     Constraints       Basel 5. Solubility     Basel     Constraints	C - Low Vellage	88175	Contract of the local division of the local	
A fact C-all Analysis A fact C-all Analysis	L L - High Voltage	84145	-	
Nati - Seriangi na Bang Gala Pangan na Bang Seriangi na Bang Seriang Seriang Seriang Serian		and the second se		
A man C and allow and a man an and a man and a man an and a man an	a - Dier Vistope		and the second s	
Gale Paradoli Bell Paradoli Reg Reg California Reg Reg California Reg Reg California Reg Reg Reg California Reg Reg Reg Reg Reg Reg Reg Reg Reg Reg	a C - Detr voltage	141	1000	
New Yorkson Annu Annu Annu Annu Annu Annu Annu An			100	1
joer 700 Pront Maria			Line .	-
Plant Editor	FORGUTTO	247		1
LAYERZERO	AUC VIC	247		
	VINE VINE A RUMAN	Ann Ann		
	VINE VINE A RUMAN	Ann Ann	0 vC	_
		n voltage n voltage n voltage nov	AL STATE AND A STATE AND A STATE AND A STATE A	MARKA         Barray         Barray           Marka         Barray         Barray

#### Zen DPQM Provides Answers

Zen DPQM provides timestamped pictures of waveforms before and after events, providing information that enables facilities to go back in time to methodically identify and correct the root causes of events. Zen actively captures power quality information at the STS, PDU, and RPP - permitting thorough post-event analysis.



### **Technical Specifications**

# Or See De Se

	Zen DPQM Parameters	Mains	Subfeeds or Branch Circuits
	Volts (L-L) Phase A/B/C (volts RMS)	✓	
Voltage Monitor	Volts (L-N) Phase A/B/C (volts RMS)	✓	
	Phase Rotation	✓	
	CT Reversed Phase A/B/C/N	✓	✓
Current Monitor	Current Phase A/B/C/N (amperes RMS)	✓	✓
	Frequency (hertz)	✓	
	Real Power (kilowatts)	✓	<ul> <li>Image: A set of the set of the</li></ul>
	Apparent Power (kilovolt-amperes)		<ul> <li>Image: A start of the start of</li></ul>
	Reactive Power (kilovolt-amperes reactive)		<ul> <li>Image: A second s</li></ul>
	Power Factor		
Power Monitor	Energy (kilowatt-hours)	Image: A state of the state	Image: A start of the start
	Block Demand (kilowatts)	Image: A start of the start	Image: A start of the start
	Block Demand Peak (kilowatts)	Image: A start of the start	Image: A start of the start
	Rolling Demand (kilowatts)		Image: A start of the start
	Rolling Demand Peak (kilowatts)	Image: A start of the start	Image: A start of the start
	Percent VTHD (percent)		Image: A start of the start
Power Quality	Waveform Capture	✓	Image: A start of the start
	Phase - Under Voltage A/B/C (Alarm)		
	Phase - Over Voltage A/B/C (Alarm)	✓	
	Phase - Low Voltage A/B/C (Warning)	✓	
	Phase - High Voltage A/B/C (Warning)	✓	
	Phase - Over Current A/B/C (Alarm)	✓	
Alarms	Phase - High Current A/B/C (Warning)	✓	<ul> <li>Image: A start of the start of</li></ul>
	Under Frequency (Alarm)		
	Over Frequency (Alarm)		
	High VTHD (Warning)		
	Over VTHD (Alarm)		
	Phase Rotation (Alarm)		

All product specifications are subject to change without notice.



## Technical Specifications

Mechanical Characteristics				
Dimensions (Single Side Distribution)	Type-maX			
	92" H x 73" W x 60" D (2337 mm H x 1854 mm W x 1524mm D)			
Weight	Please Contact LayerZero Engineering.			
Heat Dissipation	Varies on Transformer Efficiency, Please Contact LayerZero Engineering.			
Frame Construction	Welded Frame			
Color	Textured Powder Coat White (RAL 7035), Blue (RAL 5017), Black, Custom			
Seismic Floor Anchors	Optional			
Seismic Floor Stand	Optional			
Sectionalization	Dead Front Doors; Main CB(s); Monitoring; Transformer			
Electrical Characteristics				
Input Voltages	Please Contact LayerZero Engineering.			
Output Voltages	Please Contact LayerZero Engineering.			
Transformer Size	300 kVA, 400 kVA, 500 kVA			
Frequency	60 Hz			
Neutral Rating	100%, 200%			
Circuit Breaker Type	Electronic Trip, LS/I (Standard), LSI, LSI G Available, Thermal Magnetic Trip (100 AF Only)			
Distribution	SafePanel <sup>™</sup> Distribution			
Power Quality Monitoring				
Power Quality Monitoring Technology	Zen DPQM <sup>™</sup> (Distribution Power Quality Monitoring)			
Waveform Capture	Local Display, Remote Display via Web Browser			

<b>Operational Characteristics</b>	Operational Characteristics				
Cooling	Convection Cooling				
Cable Access	Top/Bottom				
Service Access	Front and Side Access; Front-Only Access; or Front/Rear Access (Type-maX FR-Only)				
IR Scan Port Type	InSight™ IR Portholes				
Display Type	3.2" LCD with Membrane, 10.5" Color Touch Screen GUI (Optional)				
Connectivity					
Meters	Local Display, Ethernet, Modbus/TCP, http via Web Browser (Non-Proprietary)				
Alarms	Local Display, Ethernet, Modbus/TCP, http via Web Browser (Non-Proprietary)				
Summary Alarm	Dry Contacts				
Waveforms	Local Display, Ethernet, http via Web Browser (Non-Proprietary)				
History/Event Log	Local Display, Ethernet, http via Web Browser (Non-Proprietary)				
Diagnostics	Local Display, Ethernet, http via Web Browser (Non-Proprietary)				
Time Synchronization	Network Time Protocol (NTP)				
Standards Conformance: Safe	Panel Distribution				
UL	ETL Listed to UL 60950				
CSA	C22.2 No 29-M1989				
	All product specifications are subject to change without notice.				







Learn more at www.LayerZero.com



LayerZero Power Systems, Inc. 1500 Danner Drive Aurora, OH 44202 U.S.A.

© 2019 LayerZero Power Systems, Inc.

LayerZero Power Systems, LayerZero.com and the LayerZero logo are registered trademark of LayerZero. All product specifications are subject to change without notice.